

Verbund




Overtopping Erosion


VERBUND Hydro Power

Perspective on Concrete Dams

Wagner, Kohler, Landstorfer
Aussois/France, 13.12.2017




VERBUND Hydro Power – 28 Large Dams in Austria



- 9 Gravity Dams (PG) ▣
 - 19 – 107 m
- 10 Arch Dams (VA) ▣
 - all double curved
 - 37 - 200 m
- 9 Embankment Dams (TE) ▣
 - 15 – 85 m

Spillways regularly in operation vs. rarely operated





- Normal water level only for a short period in autumn
- Due to pump storage not operated at normal water level

● Spillway rarely operated

● Spillway regularly operated

Slenderness factor according to Lombardi

- $K = A^2 / (V \times H)$
- A = Area of dam
- V = Volume of concrete
- H = Height of dam



Types of Spillways

- 12 – spillway on dam crest
 - 4 with an air flow
 - 8 with a chute on the dam, but no real skijump
- 5 – spillway with side weir
 - 2 with a tunnel
 - 3 with a chute on rock
 - Ending at the valley flank => water flow on unlined slope
- 3 gated spillway (1 x side weir, 2 x dam crest)
- 14 ungated spillways
- 10 with a stilling basin
 - all protected
 - 6 regularly in operation
- 7 with no stilling basin
 - 1 regularly in operation

VERBUND's experience – Hierzmann 1




- 50 % of kinetic head strain/load the bedrock (plunge pool not deep enough)
- $Q_{\max} = 22 \text{ m}^3/\text{s}$ (average $\sim 10 \text{ m}^3/\text{s}$)
- Design flood $> 300 \text{ m}^3/\text{s}$
- Duration of flood ~ 3 days

VERBUND's experience – Hierzmann 2




Hierzmann – upgrade of stilling basin



VERBUND's experience – Salza 1

- 02.06.2013 – $Q_{\max} = 76 \text{ m}^3/\text{s}$
=> No damages downstream



VERBUND's experience – Salza 2



VERBUND's experience – Margaritze 1



Perspective of picture below




SPEICHER MARGARITZE




VERBUND's experience – Margaritze 2

- 1966 – 4,7 million m³ in 6 days
 - 1987 – max. 50 m³/s
 - 2014 – max. 10 m³/s
- => No damages downstream



VERBUND's experience – Sölk

- 06.08.2017 – $Q_{\max} \sim 170 \text{ m}^3/\text{s}$
 - > 100 year flood
 - No damages downstream



VERBUND's experience – Mooserboden

- Gated Spillway test in 2008



- $Q = 10 \text{ m}^3/\text{s}$
- $Q_{\text{max}} > 100 \text{ m}^3/\text{s}$




Design requirements at time of construction


- Dams built between 1920s and 1980s
- Hydrology
 - No unified design criteria (between 100 and 5000 year flood)
- Geolocial Assessment
 - Valley flanks for side weirs with tunnel/chute
 - Influence of dip-direction of joints
 - Kind of rock mass
 - Degree of jointing
 - Exfoliation
- Statical layout
 - No uplift under stilling basins

Update of hydrology or regulations

- Spillway guideline published in 2007 by Austrian Commission on Dams/Federal Ministry for Agriculture
 - Unified hydrological design criteria
 - BHQ ~ 5000 year flood
 - Discharge only with spillway
 - SHQ = 1,3 * BHQ ~ PMF
 - Bottom outlet and headrace system can be used for discharge
 - Overtopping acceptable for existing dams in case of level raised by wind and waves
- Consequences of new guideline
 - Due to hydrological update (increased design flood), reconstruction of 3 spillways
 - 3 updates of debris control



Pack – new stilling basin due to increased design flood 1



Pack – new stilling basin due to increased design flood 2



Future research

- Numerical evaluation of stability of overflown unlined valley flank
 - Pore pressure propagation in jointed rock
 - Cavitation
- Energy dissipation of air-flow water jet
 - Pore pressure propagation in jointed rock
 - Numerical evaluation of development of scour holes
 - Stilling basin
- General research
 - Length of protection of riverbed downstream of stilling basin
 - Long term effects
 - Short term use (10 min) vs. Long term use (5 days)

Thank you for your attention!



Erich Wagner / Head of Dam Safety
Erich.Wagner@Verbund.com

Roman Kohler / Deputy Dam Safety Engineer
Roman.Kohler@Verbund.com

Florian Landstorfer / Deputy Dam Safety Engineer
Florian.Landstorfer@Verbund.com

VERBUND Hydro Power GmbH
Europaplatz 2, A-1150 Vienna
T: +43(0)50313-0
Website: www.verbund.com